




EC type-examination Certificate

Number **T10515** revision 1
Project number 12200599
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	ABB AB Arnöleden 2 SE-611 31 Nyköping Sweden
Measuring instrument	A static Active Electrical Energy Meter Type : B21, B23 and B24 Reference voltage : B21: 220V ... 240V B23 / B24: 3x220/380V...3x240/415V or 3x380V...3x415V Reference current : B21 / B23: 5A (direct connected meter) B24: 1 A (indirect connected meter) Destined for the measurement of : electrical energy, in a - three-phase four-wire network (B23 / B24) - three-phase three-wire network (B23 / B24) - single-phase two-wire network (B21) Accuracy class : B21 / B23: A or B B24: B or C Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10515 revision 1; - Documentation folder T10515-2.
Valid until	11 July 2023
Remarks	This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
19 September 2013


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.
The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMI (see www.nmi.nl).

Reproduction of the complete
document only is permitted.

